



- Notes:
1. The compressor condensing unit should be indoor located, while the evaporative condenser outdoor;
 2. Distance between the evaporative condenser and compressor condensing unit should be within 10 meters, and at least 1 meter higher.
 3. All water, power, and refrigeration pipelines should be connected to SNOWMAN designated ports.
 4. The dimensions are for your reference only, which is subject to the actual size.
 5. At least 1 meter service room surrounded is better.
 6. Without special instruction, please do follow SNOWMAN regulation.
 7. The drawing is for your reference only. Refer to the Contract for detailed supply scope.

Dibujado	Revisado	
A. LARA		
Escala	CLIENTE:	Numero de plano
	TITULO:	01
	ESQUEMA DE PRINCIPIO ENFRIAMIENTO DEL HORMIGON TODO AIRE	